

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7315-1496:144 Page 1 of 1

**CATEGORY:** Power Units

**LISTEE:** Firecom Inc., 39-27 59<sup>th</sup> Street, Woodside, NY 11377  
Contract: Howard Kogen (718) 899-6100

**DESIGN:** Models FAL400ULX and FAL400ULM power supply units. Model FAL400ULM is basically an FAL400ULX with a MOM5 multi-output power module. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 115 VAC input, 12 or 24 VDC output

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For fire alarm use, the standby batteries must provide 24 hours standby power during power loss.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as power supply units for use with separately listed compatible fire alarm control units to provide power for door holders, door strikes or similar devices.

**NOTE:** Not suitable for fire alarm indicating devices.

**XLF:** 7315-1335:100

12-09-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 19, 2001**

*Listing Expires **June 30, 2002***

Authorized By:

**BEN HO**, Supervising Deputy  
Program Manager